

SCHOOL FACILITY INFORMATION

TEST INFORMATION

MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN

ADDITIONAL INFORMATION

School District Number

Ministry Facility Code

School Facility Name

Year

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION			
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period

SCHOOL FACILITY INFORMATION

TEST INFORMATION

MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN

ADDITIONAL INFORMATION

School

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161013	Oaklands Elementary	1913	Aug 19	1	Water Fountain	CLASS 2010	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug 22	30 Mar 22
61	06161013	Oaklands Elementary	1913	Mar 21	1	Water Fountain	CLASS 3010	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161013	Oaklands Elementary	1913	Aug 19	1	Water Fountain	CLASS 3005	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug 22	30 Mar 22
61	06161013	Oaklands Elementary	1913	Mar 21	1	Water Fountain	CLASS 3001	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161013	Oaklands Elementary	1913	Mar 21	1	Sink	STAFF 1050	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161013	Oaklands Elementary	1913	Aug 19	1	Sink	KITCH 1027	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Aug 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Nov 19	1	Water Filling Station	CORRIDOR 1015	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Water Filling Station	CORRIDOR 1034	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Nov 19	1	Water Filling Station	CORRIDOR 1054	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Nov 19	1	Water Filling Station	CORRIDOR 2022	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Water Filling Station	CORRIDOR 2038	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Aug 19	2	Water Filling Station	CORRIDOR 2070	0.001	No	30 Sec flush before use until filter can Information is provided to School staf None.			Aug 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Water Filling Station	CORRIDOR 2070	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1024	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1024	0.005	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1024	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1024	0.005	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1024	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1024	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Sink	CLASS 1027	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1033	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1033	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1033	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1033	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1033	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Oct 19	1	Sink	FOODS 1033	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Jul 19	1	Sink	KITCH 1065	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Jul 19	1	Sink	CLASS 2076	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Jul 19	1	Sink	STAFF 2042	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul 22	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Sink	KITCH 1065	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Sink	CLASS 1044	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Mar 21	1	Sink	CLASS 2076	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161057	Reynolds Secondary	1966	Nov 19	1	Sink	MEDIC 2078	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Nov 22	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Water Fountain	CORRIDOR 1056	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Water Fountain	CORRIDOR 1003	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Water Fountain	CORRIDOR 1054	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Sink	MEDIC 1004	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Sink	STAFF 1053	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Sink	FOODS 2019	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Water Fountain	CORRIDOR 1039	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Mar 21	1	Water Fountain	CORRIDOR 2015	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Mar 24	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Water Fountain	CORRIDOR 2030	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Jan 20	1	Sink	KITCH 1013	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jan 23	30 Mar 22
61	06161060	Richmond Elementary	1967	Mar 21	lead staf 1	Sink	CLwith						Jan 23	30 Mar 22

SCHOOL FACILITY INFORMATION				TEST INFORMATION			MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION	
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation	

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
61	06161018	Victoria High	1911	Oct 19	1	Sink	FOODS 1013	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161018	Victoria High	1911	Dec 19	1	Sink	KITCH 2020	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161018	Victoria High	1911	Dec 19	1	Water Fountain	GYM 0030	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Water Filling Station	CORRIDOR 1064	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Water Fountain	CORRIDOR 1064	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Feb 21	1	Sink	MEDIC 1057	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb 24	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Sink	STAFF 1055	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Water Fountain	CORRIDOR 1049	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Water Filling Station	CORRIDOR 1049	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Water Fountain	CORRIDOR 1032	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Sink	ANNEX A1001	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Feb 21	1	Sink	KITCH 1038	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb 24	30 Mar 22
61	06161004	Victoria West Elementary	1969	Dec 19	1	Sink	KITCH 1038	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Dec 22	30 Mar 22
61	06161004	Victoria West Elementary	1969	Feb 21	1	Sink	KITCH 1038	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Feb 24	30 Mar 22
61	06161029	View Royal Elementary	1948	Jul 19	1	Sink	DAYCARE	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Jul 19	1	Sink	DAYCARE	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Jul 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Water Filling Station	CORRIDOR 1065	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Sink	MEDIC 1007A	0.003	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Sink	STAFF 1042	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Water Filling Station	CORRIDOR 1019	0.000	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Sink	CLASS 0027	0.004	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Water Fountain	DAYCARE	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Water Fountain	CORRIDOR 1031	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Sink	KITCH 1044	0.002	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22
61	06161029	View Royal Elementary	1948	Oct 19	1	Sink	DAYCARE	0.001	No	Lead filter installed with lead free fixt. Information is provided to School staf None.			Oct 22	30 Mar 22