## **VENTILATION SYSTEM OVERVIEW**

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	61 - Greater Victoria	
School Name:		
	facilities 2nd floor	
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes	
	Date of last inspection: 2023-06-12	
	Date of next inspection: 2023-10-12	
	Date and type of most recent maintenance: 23-06-12 turn heat off in main boardroom	
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes	
	Detail: DDC and or manually, opened to as close to 100% as possible	
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: No	
	Detail (Including filter grade): We are using pleated Merv 10 filters and changed out every three months.	
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No	
	Detail: We looked at Ultraviolet Germicidal Irradiation. UVGI can cause temp eye irritation, sunburn effects and if exposed long enough, may cause cancer. The virus is new and though researchers are attempting to find out if this technology works there is not enough evidence it kills the virus.	
tr	We looked at Needlepoint Ionization and though it cleans the air there is no independent research that says it kills the virus. There is research retlina(co)-പ്രവാദ്യമുട്ടിയുന്നു പ്രവാദ്യമുട്ടിയുന്നു പ്രവാദ്യമുട്ടിയുന്നു പരിച്ചു പരിച്ചു പരിച്ചു പരിച്ചുള്ള പരിച്ചു പരിച്ചു പരിച്ചുള്ള പരിച്ചു പരിച്ചുള്ള പരവരിച്ചുള്ള പരിച്ചുള്ള പരവര് പരവര്യ പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരവര്യ പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരവര്യ പരിച്ച്ചുള്ള പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരിച്ചുള്ള പരിച്ചുള്ള പരവര്യ പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരിച്ചുള്ള പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരിപരവര്യ പരിപരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പരവര്യ പ	łref216.12 16-6.
	Yes	
	Detail:  To the best of our ability. However when we need to our fresh air is running near 100%, windows open and recently, to assist with extraction many fans such as washroom fans may be running 24/7. We know this is an issue with our Energy Manager but trying to remove	

	possible air contamination is paramount.
Other Relevant Information:	We are on top of this and do respond quickly to teacher complaints.  We want to ensure communication and try to keep staff informed and calm.
District Contact for any Questions:	Name: Domenic Ferrarelli