

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

	61 - Greater Victoria
	Rogers Elementary
Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2023-06-14

Upgrade filtration, including installing MERV-13 filters, where possible

Use other air cleaning or treatment technologies

We looked at Needlepoint Ionization and though it cleans the air there is no independent research that says it kills the virus. There is research that suggests the molecular structure of disrupted ions may creates harmful VOC, etc. We will not use this.

	possible air contamination is paramount.
	We are on top of this and do respond quickly to teacher complaints. We want to ensure communication and try to keep staff informed and calm.
	Name: Domenic Ferrarelli