

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance and staff safety throughout the pandemic.

School District:	61 - Greater Victoria
School Name:	Tillicum Elementary
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2023-05-12
	Date of next inspection: 2023-08-14
	Date and type of most recent maintenance: 23-08-14 Gym Roof-EF-Bearings are shot
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: DDC and or manuE6 are s:

VENTILATION